



NORTH PEKIN – MARQUETTE HEIGHTS SCHOOL DISTRICT #102

Byron Sondgeroth, Superintendent
51 Yates Rd.
Marquette Heights, IL 61554

Phone: 309-382-2172
Fax: 309-382-2122
www.dist102.org

November 14, 2017

Dear District 102 Parents/Guardians,

Illinois Public Act 099-0 922 requires all Pre-K through 5th grade schools built before January 1, 2000 to test the level of lead in the water from every outlet that could be used for drinking or food preparation. Each water outlet must be sampled twice. An IEPA (Illinois Environmental Protection Agency) accredited laboratory must be utilized for the analysis. After a school receives its results, any sample exceeding 5 ppb (parts per billion) or 5 ug/l (micrograms per liter) of lead requires the district to notify parents and create a mitigation plan. All results must be submitted to the Illinois Department of Public Health. (Please note that the level set by the State is significantly lower than the Federal Government threshold of 15 ppb or ug/l for public water systems and 20 ppb or ug/l recommended by the EPA for school outlets.). Testing must occur prior to December 31, 2017.

On October 25, District 102 collected samples on a total of 7 water outlets at Rogers School. On October 26, District 102 collected samples on 8 water outlets at Marquette School. The two samples from each location were then submitted to PDC Laboratories in Peoria for analysis on October 30. The results were returned to District 102 on November 14. Those results showed that all of the 15 outlets tested at Rogers and Marquette Schools had lead levels well below the maximum allowable level of 5 ug/l. In short, all of the District 102 faucets tested at an acceptable level and no mitigation plan is required.

As required by law, a notification to parents will be posted on the district website. The test results will also be emailed to Illinois Department of Health (IDPH). Full reports for both Marquette and Rogers Schools from PDC Laboratories are attached to this letter.

Additional information about lead in drinking water can be found on the USEPA website:
<https://www.epa.gov/ground-water-and-drinking-water/basic-information-about-lead-drinking-water>.

Sincerely,

Byron Sondgeroth
Superintendent

Georgetown Middle School
51 Yates Road
Marquette Heights, IL 61554
309-382-3456

Rogers Elementary School
109 Rogers Road
Marquette Heights, IL 61554
309-382-3401

Marquette Elementary School
100 Joliet Road
Marquette Heights, IL 61554
309-382-3612



PDC Laboratories, Inc.

PROFESSIONAL • DEPENDABLE • COMMITTED

November 14, 2017

Marquette School Report

Byron Sondgeroth
North Pekin-Marquette Heights School District 102
51 Yates Road
Marquette Heights, IL 61554

Dear Byron Sondgeroth:

Please find enclosed the analytical results for the sample(s) the laboratory received on **10/30/17 1:30 pm** and logged in under work order **7104914**. All testing is performed according to our current TNI certifications unless otherwise noted. This report cannot be reproduced, except in full, without the written permission of PDC Laboratories, Inc.

If you have any questions regarding your report, please contact your project manager. Quality and timely data is of the utmost importance to us.

PDC Laboratories, Inc. appreciates the opportunity to provide you with analytical expertise. We are always trying to improve our customer service and we welcome you to contact the Vice President, John LaPayne with any feedback you have about your experience with our laboratory.

Sincerely,

A handwritten signature in black ink, appearing to read 'Kurt Stepping'.

Senior Project Manager
(309) 692-9688 x1719
kstepping@pdclab.com





Marquette School Report

PDC Laboratories, Inc.

2231 West Altorfer Drive

Peoria, IL 61615

(800) 752-6651

ANALYTICAL RESULTS

Sample: 7104914-01
Name: M1A 1ST
Alias: MES

Sampled: 10/26/17 06:38
Received: 10/30/17 13:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	4.00	ug/L		11/10/17 11:10	11/13/17 11:46	KMC	EPA 200.8

Sample: 7104914-02
Name: M1B 2ND
Alias: MES

Sampled: 10/26/17 06:40
Received: 10/30/17 13:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		11/10/17 11:10	11/13/17 11:47	KMC	EPA 200.8

Sample: 7104914-03
Name: M2A 1ST
Alias: MES

Sampled: 10/26/17 06:43
Received: 10/30/17 13:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		11/10/17 11:10	11/13/17 11:48	KMC	EPA 200.8

Sample: 7104914-04
Name: M2B 2ND
Alias: MES

Sampled: 10/26/17 06:44
Received: 10/30/17 13:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		11/10/17 11:10	11/13/17 11:50	KMC	EPA 200.8

Sample: 7104914-05
Name: M3A 1ST
Alias: MES

Sampled: 10/26/17 06:50
Received: 10/30/17 13:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		11/10/17 11:10	11/13/17 11:51	KMC	EPA 200.8



ANALYTICAL RESULTS

Sample: 7104914-06
Name: M3B 2ND
Alias: MES

Sampled: 10/26/17 06:51
Received: 10/30/17 13:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		11/10/17 11:10	11/13/17 11:52	KMC	EPA 200.8

Sample: 7104914-07
Name: M4A 1ST
Alias: MES

Sampled: 10/26/17 06:13
Received: 10/30/17 13:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		11/10/17 11:10	11/13/17 11:54	KMC	EPA 200.8

Sample: 7104914-08
Name: M4B 2ND
Alias: MES

Sampled: 10/26/17 06:15
Received: 10/30/17 13:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		11/10/17 11:10	11/13/17 12:01	KMC	EPA 200.8

Sample: 7104914-09
Name: M5A 1ST
Alias: MES

Sampled: 10/26/17 06:18
Received: 10/30/17 13:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		11/10/17 11:10	11/13/17 12:02	KMC	EPA 200.8

Sample: 7104914-10
Name: M5B 2ND
Alias: MES

Sampled: 10/26/17 06:19
Received: 10/30/17 13:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		11/10/17 11:10	11/13/17 12:03	KMC	EPA 200.8



ANALYTICAL RESULTS

Sample: 7104914-11
Name: M6A 1ST
Alias: MES

Sampled: 10/26/17 06:22
Received: 10/30/17 13:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		11/10/17 11:10	11/13/17 12:05	KMC	EPA 200.8

Sample: 7104914-12
Name: M6B 2ND
Alias: MES

Sampled: 10/26/17 06:24
Received: 10/30/17 13:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		11/10/17 11:10	11/13/17 12:06	KMC	EPA 200.8

Sample: 7104914-13
Name: M7A 1ST
Alias: MES

Sampled: 10/26/17 06:27
Received: 10/30/17 13:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		11/10/17 11:10	11/13/17 12:07	KMC	EPA 200.8

Sample: 7104914-14
Name: M7B 2ND
Alias: MES

Sampled: 10/26/17 06:28
Received: 10/30/17 13:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		11/10/17 11:10	11/13/17 12:08	KMC	EPA 200.8

Sample: 7104914-15
Name: M8A 1ST
Alias: MES

Sampled: 10/26/17 06:31
Received: 10/30/17 13:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		11/10/17 11:10	11/13/17 12:38	KMC	EPA 200.8



ANALYTICAL RESULTS

Sample: 7104914-16
Name: M8B 2ND
Alias: MES

Sampled: 10/26/17 06:32
Received: 10/30/17 13:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		11/10/17 11:10	11/13/17 12:39	KMC	EPA 200.8

Sample: 7104914-17
Name: M9A 1ST
Alias: MES

Sampled: 10/26/17 06:34
Received: 10/30/17 13:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		11/10/17 11:10	11/13/17 12:41	KMC	EPA 200.8

Sample: 7104914-18
Name: M9B 2ND
Alias: MES

Sampled: 10/26/17 06:35
Received: 10/30/17 13:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		11/10/17 11:10	11/13/17 12:10	KMC	EPA 200.8



PDC Laboratories, Inc.

2231 West Altorfer Drive

Peoria, IL 61615

(800) 752-6651

NOTES

Specific method revisions used for analysis are available upon request.

Certifications

CHI - McHenry, IL

TNI Accreditation for Drinking Water, Wastewater, Hazardous and Solid Wastes Fields of Testing through IL EPA Lab No. 100279
Illinois Department of Public Health Bacteriological Analysis in Drinking Water Approved Laboratory Registry No. 17556

PIA - Peoria, IL

TNI Accreditation for Drinking Water, Wastewater, Hazardous and Solid Wastes Fields of Testing through IL EPA Lab No. 100230
Illinois Department of Public Health Bacteriological Analysis in Drinking Water Approved Laboratory Registry No. 17553
Wastewater Certifications: Arkansas (88-0677); Iowa (240); Kansas (E-10338)
Hazardous/Solid Waste Certifications: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

SPMO - Springfield, MO

USEPA DMR-QA Program

STL - St. Louis, MO

TNI Accreditation for Wastewater, Hazardous and Solid Wastes Fields of Testing through KS Lab No. E-10389
Illinois Department of Public Health Bacteriological Analysis in Drinking Water Approved Laboratory Registry No. 171050
Drinking Water Certifications: Missouri (1050)
Missouri Department of Natural Resources

* Not a TNI accredited analyte

Certified by: Kurt Stepping, Senior Project Manager



PDC LABORATORIES, INC.
 2231 WEST ALTORFER DRIVE
 PEORIA, IL 61615
 PHONE: (800) 752-6651 FAX: (309) 692-9688

CHAIN OF CUSTODY RECORD
 ILLINOIS SCHOOLS LEAD TESTING

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT N. Pekin - Marq. Hts. Dist 102		P.O. NUMBER		SCHOOL NAME Marquette School		MEANS SHIPPED		3 ANALYSIS REQUESTED				4 (FOR LAB USE ONLY)	
ADDRESS 51 Yates Rd.		PHONE NUMBER 309 382-2172		EMAIL bsondgeroth@dist102.org		DATE SHIPPED		LEAD 200.8				LOGIN #	
CITY STATE ZIP Marquette Heights, IL		5 (PLEASE PRINT) SAMPLER'S NAME Jim Prince		MATRIX TYPES: WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL- SLUDGE NAS- SOLID LCHT- LEACHATE		DATE SHIPPED						LOGGED BY:	
CONTACT PERSON Byron Sondgeroth		SAMPLER'S SIGNATURE Jim Prince		OTHER:		DATE SHIPPED						LAB PROJ. #	
2 SAMPLE DESCRIPTION AS YOU WANT ON REPORT		DATE COLLECTED	TIME COLLECTED	SAMPLE VOLUME COLLECTED	MATRIX TYPE	BOTTLE COUNT					DATE/TIME LAST USED		
MES M6A (first draw)	10/26/17	6:22	250 ml	DW	1	X						10/25/17 9 PM	
MES M6B (second draw)	10/26/17	6:24	250 ml	DW	1	X						10/25/17 9 PM	
MES M7A (first draw)	10/26/17	6:27	250 ml	DW	1	X						10/25/17 9 PM	
MES M7B (second draw)	10/26/17	6:28	250 ml	DW	1	X						10/25/17 9 PM	
MES M8A (first draw)	10/26/17	6:31	250 ml	DW	1	X						10/25/17 9 PM	
MES M8B (second draw)	10/26/17	6:32	250 ml	DW	1	X						10/25/17 9 PM	
MES M9A (first draw)	10/26/17	6:34	250 ml	DW	1	X						10/25/17 9 PM	
MES M9B (second draw)	10/26/17	6:35	250 ml	DW	1	X						10/25/17 9 PM	
				ml	DW	1	X						
				ml	DW	1	X						
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) NORMAL RUSH		DATE RESULTS NEEDED		6 The sample temperature will be measured upon receipt at the lab. By initialing this area you request that the lab notify you, before proceeding with analysis, if the sample temperature is outside of the range of 0.1-6.0°C. By not initialing this area you allow the lab to proceed with analytical testing regardless of the sample temperature.									
RUSH RESULTS VIA (PLEASE CIRCLE) FAX PHONE		DATE RESULTS NEEDED											
FAX # IF DIFFERENT FROM ABOVE:		PHONE # IF DIFFERENT FROM ABOVE:											
7 RELINQUISHED BY: (SIGNATURE) Byron Sondgeroth		DATE 10/30/17	TIME 1:29 PM	RECEIVED BY: (SIGNATURE)		DATE	TIME	8 COMMENTS: (FOR LAB USE ONLY)					
RELINQUISHED BY: (SIGNATURE)		DATE	TIME	RECEIVED BY: (SIGNATURE)		DATE	TIME	SAMPLE TEMPERATURE UPON RECEIPT 21 °C					
RELINQUISHED BY: (SIGNATURE)		DATE	TIME	RECEIVED BY: (SIGNATURE)		DATE 10/31/17	TIME 1:30	CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N SAMPLE(S) RECEIVED ON ICE Y OR N PROPER BOTTLES RECEIVED IN GOOD CONDITION Y OR N BOTTLES FILLED WITH ADEQUATE VOLUME Y OR N SAMPLES RECEIVED WITHIN HOLD TIME(S) (EXCLUDES TYPICAL FIELD PARAMETERS) Y OR N DATE AND TIME TAKEN FROM SAMPLE BOTTLE					

PDC LABORATORIES, INC.
 2231 WEST ALTORFER DRIVE
 PEORIA, IL 61615
 PHONE: (800) 752-6651 FAX: (309) 692-9688

CHAIN OF CUSTODY RECORD
 ILLINOIS SCHOOLS LEAD TESTING

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT N. Pekin - Marg. Hts. Dist 102		P.O. NUMBER	SCHOOL NAME Marguerite School		MEANS SHIPPED		3 ANALYSIS REQUESTED		4 (FOR LAB USE ONLY) a-7604914-18		
ADDRESS 51 Yates Rd.		PHONE NUMBER 309 382-2172	EMAIL bsondgeroth@dist102.org		DATE SHIPPED		LEAD 200.8		LOGIN #		
CITY STATE ZIP Marguerite Heights, IL		SAMPLER'S SIGNATURE Jim Prince		MATRIX TYPES: WW-WASTEWATER DW-DRINKING WATER GW-GROUND WATER WWSL-SLUDGE NAS-SOLID LCHT-LEACHATE		LAB PROJ. #			LOGGED BY: <i>ku</i>		
CONTACT PERSON Byron Sondgeroth		SAMPLER'S SIGNATURE Jim Prince		OTHER:		TEMPLATE:			PROJ. MGR.: KURT STEPPING		
2 SAMPLE DESCRIPTION AS YOU WANT ON REPORT		DATE COLLECTED	TIME COLLECTED	SAMPLE VOLUME COLLECTED	MATRIX TYPE	BOTTLE COUNT			DATE/TIME LAST USED		
MES M1A (first draw)		10/26/17	6:38	250 ml	DW	1	X			10/25/17 9 PM	
MES M1B (Second draw)		10/26/17	6:40	250 ml	DW	1	X			10/25/17 9 PM	
MES M2A (first draw)		10/26/17	6:43	250 ml	DW	1	X			10/25/17 9 PM	
MES M2B (Second draw)		10/26/17	6:44	250 ml	DW	1	X			10/25/17 9 PM	
MES M3A (first draw)		10/26/17	6:50	250 ml	DW	1	X			10/25/17 9 PM	
MES M3B (Second draw)		10/26/17	6:51	250 ml	DW	1	X			10/25/17 9 PM	
MES M4A (first draw)		10/26/17	6:13	250 ml	DW	1	X			10/25/17 9 PM	
MES M4B (Second draw)		10/26/17	6:15	250 ml	DW	1	X			10/25/17 9 PM	
MES M5A (first draw)		10/26/17	6:18	250 ml	DW	1	X			10/25/17 9 PM	
MES M5B (Second draw)		10/26/17	6:19	250 ml	DW	1	X			10/25/17 9 PM	
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) NORMAL RUSH (RUSH THAT IS SUBJECT TO PDC LABS APPROVAL AND SURCHARGE)		DATE RESULTS NEEDED		6 The sample temperature will be measured upon receipt at the lab. By initiating this area you request that the lab notify you, before proceeding with analysis, if the sample temperature is outside of the range of 0-16.0°C. By not initiating this area you allow the lab to proceed with analytical testing regardless of the sample temperature.							
RUSH RESULTS VIA (PLEASE CIRCLE) FAX PHONE		FAX PHONE		FAX PHONE		FAX PHONE		FAX PHONE		FAX PHONE	
7 RELINQUISHED BY: (SIGNATURE) <i>Byron Sondgeroth</i>		DATE 10/30/17	TIME 1:29 PM	RECEIVED BY: (SIGNATURE)		DATE	TIME	8 COMMENTS: (FOR LAB USE ONLY)			
RELINQUISHED BY: (SIGNATURE)		DATE	TIME	RECEIVED BY: (SIGNATURE)		DATE	TIME	SAMPLE TEMPERATURE UPON RECEIPT 21 °C			
RELINQUISHED BY: (SIGNATURE)		DATE	TIME	RECEIVED BY: (SIGNATURE) <i>ku</i>		DATE 10/30/17	TIME 1:53	CHILL PROCESS STARTED PRIOR TO RECEIPT SAMPLE(S) RECEIVED ON ICE PROPER BOTTLES RECEIVED IN GOOD CONDITION BOTTLES FILLED WITH ADEQUATE VOLUME SAMPLES RECEIVED WITHIN HOLD TIME(S) (EXCLUDES TYPICAL FIELD PARAMETERS) DATE AND TIME TAKEN FROM SAMPLE BOTTLE			



PDC Laboratories, Inc.

PROFESSIONAL • DEPENDABLE • COMMITTED

November 14, 2017

Byron Sondgeroth
North Pekin-Marquette Heights School District 102
51 Yates Road
Marquette Heights, IL 61554

Rogers School Report

Dear Byron Sondgeroth:

Please find enclosed the analytical results for the sample(s) the laboratory received on **10/30/17 1:30 pm** and logged in under work order **7104915**. All testing is performed according to our current TNI certifications unless otherwise noted. This report cannot be reproduced, except in full, without the written permission of PDC Laboratories, Inc.

If you have any questions regarding your report, please contact your project manager. Quality and timely data is of the utmost importance to us.

PDC Laboratories, Inc. appreciates the opportunity to provide you with analytical expertise. We are always trying to improve our customer service and we welcome you to contact the Vice President, John LaPayne with any feedback you have about your experience with our laboratory.

Sincerely,

A handwritten signature in black ink, appearing to read "Kurt Stepping".

Senior Project Manager
(309) 692-9688 x1719
kstepping@pdclab.com





Rogers School Report

PDC Laboratories, Inc.

2231 West Altorfer Drive

Peoria, IL 61615

(800) 752-6651

ANALYTICAL RESULTS

Sample: 7104915-01

Name: R1A 1ST

Alias: ROGERS

Sampled: 10/25/17 05:44

Received: 10/30/17 13:30

Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	---------	--------

Total Metals - PIA

Lead	1.04	ug/L		11/13/17 07:43	11/13/17 08:32	KMC	EPA 200.8
------	------	------	--	----------------	----------------	-----	-----------

Sample: 7104915-02

Name: R1B 2ND

Alias: ROGERS

Sampled: 10/25/17 05:46

Received: 10/30/17 13:30

Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		11/13/17 07:43	11/13/17 08:33	KMC	EPA 200.8
------	--------	------	--	----------------	----------------	-----	-----------

Sample: 7104915-03

Name: R2A 1ST

Alias: ROGERS

Sampled: 10/25/17 05:49

Received: 10/30/17 13:30

Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	---------	--------

Total Metals - PIA

Lead	1.29	ug/L		11/13/17 07:43	11/13/17 08:45	KMC	EPA 200.8
------	------	------	--	----------------	----------------	-----	-----------

Sample: 7104915-04

Name: R2B 2ND

Alias: ROGERS

Sampled: 10/25/17 05:51

Received: 10/30/17 13:30

Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		11/13/17 07:43	11/13/17 08:47	KMC	EPA 200.8
------	--------	------	--	----------------	----------------	-----	-----------

Sample: 7104915-05

Name: R3A 1ST

Alias: ROGERS

Sampled: 10/25/17 05:53

Received: 10/30/17 13:30

Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	---------	--------

Total Metals - PIA

Lead	4.40	ug/L		11/13/17 07:43	11/13/17 08:48	KMC	EPA 200.8
------	------	------	--	----------------	----------------	-----	-----------



ANALYTICAL RESULTS

Sample: 7104915-06
Name: R3B 2ND
Alias: ROGERS

Sampled: 10/25/17 05:55
Received: 10/30/17 13:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		11/13/17 07:43	11/13/17 08:49	KMC	EPA 200.8

Sample: 7104915-07
Name: R4A 1ST
Alias: ROGERS

Sampled: 10/25/17 05:57
Received: 10/30/17 13:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	2.82	ug/L		11/13/17 07:43	11/13/17 08:51	KMC	EPA 200.8

Sample: 7104915-08
Name: R4B 2ND
Alias: ROGERS

Sampled: 10/25/17 05:59
Received: 10/30/17 13:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		11/13/17 07:43	11/13/17 08:52	KMC	EPA 200.8

Sample: 7104915-09
Name: R5A 1ST
Alias: ROGERS

Sampled: 10/25/17 06:03
Received: 10/30/17 13:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		11/13/17 07:43	11/13/17 08:53	KMC	EPA 200.8

Sample: 7104915-10
Name: R5B 2ND
Alias: ROGERS

Sampled: 10/25/17 06:04
Received: 10/30/17 13:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		11/13/17 07:43	11/13/17 08:55	KMC	EPA 200.8



ANALYTICAL RESULTS

Sample: 7104915-11
Name: R6A 1ST
Alias: ROGERS

Sampled: 10/25/17 06:07
Received: 10/30/17 13:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		11/13/17 07:43	11/13/17 09:05	KMC	EPA 200.8

Sample: 7104915-12
Name: R6B 2ND
Alias: ROGERS

Sampled: 10/25/17 06:09
Received: 10/30/17 13:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		11/13/17 07:43	11/13/17 09:06	KMC	EPA 200.8

Sample: 7104915-13
Name: R7A 1ST
Alias: ROGERS

Sampled: 10/25/17 06:11
Received: 10/30/17 13:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		11/13/17 07:43	11/13/17 09:08	KMC	EPA 200.8

Sample: 7104915-14
Name: R7B 2ND
Alias: ROGERS

Sampled: 10/25/17 06:13
Received: 10/30/17 13:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		11/13/17 07:43	11/13/17 09:09	KMC	EPA 200.8



PDC Laboratories, Inc.

2231 West Altorfer Drive

Peoria, IL 61615

(800) 752-6651

NOTES

Specific method revisions used for analysis are available upon request.

Certifications

CHI - McHenry, IL

TNI Accreditation for Drinking Water, Wastewater, Hazardous and Solid Wastes Fields of Testing through IL EPA Lab No. 100279
Illinois Department of Public Health Bacteriological Analysis in Drinking Water Approved Laboratory Registry No. 17556

PIA - Peoria, IL

TNI Accreditation for Drinking Water, Wastewater, Hazardous and Solid Wastes Fields of Testing through IL EPA Lab No. 100230
Illinois Department of Public Health Bacteriological Analysis in Drinking Water Approved Laboratory Registry No. 17553
Wastewater Certifications: Arkansas (88-0677); Iowa (240); Kansas (E-10338)
Hazardous/Solid Waste Certifications: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

SPMO - Springfield, MO

USEPA DMR-QA Program

STL - St. Louis, MO

TNI Accreditation for Wastewater, Hazardous and Solid Wastes Fields of Testing through KS Lab No. E-10389
Illinois Department of Public Health Bacteriological Analysis in Drinking Water Approved Laboratory Registry No. 171050
Drinking Water Certifications: Missouri (1050)
Missouri Department of Natural Resources

* Not a TNI accredited analyte

Certified by: Kurt Stepping, Senior Project Manager



PDC LABORATORIES, INC.
 2231 WEST ALTORFER DRIVE
 PEORIA, IL 61615
 PHONE: (800) 752-6651 FAX: (309) 692-9688

CHAIN OF CUSTODY RECORD
 ILLINOIS SCHOOLS LEAD TESTING

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT N. Pekin - Marq. Hts. Dist 102		P.O. NUMBER	SCHOOL NAME Rogers School		MEANS SHIPPED		3 ANALYSIS REQUESTED			4 (FOR LAB USE ONLY) LOGIN # 104915-100			
ADDRESS 51 Yates Rd.		PHONE NUMBER 309 382-2172	EMAIL bsondgeroth@dist102.org		DATE SHIPPED		LEAD 200.8			LOGGED BY: <i>[Signature]</i>			
CITY Marquette Heights, IL	SAMPLER (PLEASE PRINT) Jim Prince		MATRIX TYPES: WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL- SLUDGE NAS- SOLID LCHL- LEACHATE		LAB PROJ. #					TEMPLATE:		PROJ. MGR.: KURT STEPPING	
STATE IL	SAMPLER (PLEASE PRINT) Jim Prince		OTHER:		DATE/TIME LAST USED								
CONTACT PERSON Byron Sondgeroth		DATE COLLECTED		TIME COLLECTED	SAMPLE VOLUME COLLECTED	MATRIX TYPE	BOTTLE COUNT						
2 SAMPLE DESCRIPTION AS YOU WANT ON REPORT		DATE COLLECTED		TIME COLLECTED	SAMPLE VOLUME COLLECTED	MATRIX TYPE	BOTTLE COUNT						
Rogers R1A (first draw)		10/25/17	5:44 AM	250	ml	DW	1	X	10/24/17 7 PM				
Rogers R1B (second draw)		10/25/17	5:46 AM	250	ml	DW	1	X	10/24/17 7 PM				
Rogers R2A (first draw)		10/25/17	5:49 AM	250	ml	DW	1	X	10/24/17 7 PM				
Rogers R2B (second draw)		10/25/17	5:51 AM	250	ml	DW	1	X	10/24/17 7 PM				
Rogers R3A (first draw)		10/25/17	5:53 AM	250	ml	DW	1	X	10/24/17 7 PM				
Rogers R3B (second draw)		10/25/17	5:55 AM	250	ml	DW	1	X	10/24/17 7 PM				
Rogers R4A (first draw)		10/25/17	5:57 AM	250	ml	DW	1	X	10/24/17 7 PM				
Rogers R4B (second draw)		10/25/17	5:59 AM	250	ml	DW	1	X	10/24/17 7 PM				
Rogers R5A (first draw)		10/25/17	6:03 AM	250	ml	DW	1	X	10/24/17 7 PM				
Rogers R5B (second draw)		10/25/17	6:04 AM	250	ml	DW	1	X	10/24/17 7 PM				
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) NORMAL RUSH		RUSH RESULTS VIA (PLEASE CIRCLE) FAX PHONE		DATE RESULTS NEEDED		5 The sample temperature will be measured upon receipt at the lab. By initiating this area you request that the lab notify you, before proceeding with analysis, if the sample temperature is outside of the range of 0.1-6.0°C. By not initiating this area you allow the lab to proceed with analytical testing regardless of the sample temperature.							
7 RELINQUISHED BY: (SIGNATURE) <i>[Signature]</i>		DATE 10/30/17	TIME 1:25 PM	RECEIVED BY: (SIGNATURE)		DATE	TIME	8 COMMENTS: (FOR LAB USE ONLY)					
RELINQUISHED BY: (SIGNATURE)		DATE	TIME	RECEIVED BY: (SIGNATURE)		DATE	TIME	SAMPLE TEMPERATURE UPON RECEIPT 21 °C					
RELINQUISHED BY: (SIGNATURE)		DATE	TIME	RECEIVED BY: (SIGNATURE) <i>[Signature]</i>		DATE 10/30/17	TIME 1:30	CHILL PROCESS STARTED PRIOR TO RECEIPT SAMPLE(S) RECEIVED ON ICE PROPER BOTTLES RECEIVED IN GOOD CONDITION BOTTLES FILLED WITH ADEQUATE VOLUME SAMPLES RECEIVED WITHIN HOLD TIME(S) (EXCLUDES TYPICAL FIELD PARAMETERS) DATE AND TIME TAKEN FROM SAMPLE BOTTLE					

PDC LABORATORIES, INC.
 2231 WEST ALTORFER DRIVE
 PEORIA, IL 61615
 PHONE: (800) 752-6651 FAX: (309) 692-9688

CHAIN OF CUSTODY RECORD ILLINOIS SCHOOLS LEAD TESTING

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

<p>1 CLIENT N. Pekin-Marg. Hts. Dist 102</p> <p>ADDRESS 51 Yates Rd.</p> <p>CITY STATE ZIP Marquette Heights, IL</p> <p>CONTACT PERSON Byron Sondgeroth</p>	<p>P.O. NUMBER</p> <p>PHONE NUMBER 309 382-2172</p> <p>SAMPLER (PLEASE PRINT) Jim Prince</p> <p>SAMPLER'S SIGNATURE <i>Jim Prince</i></p>	<p>SCHOOL NAME Rogers School</p> <p>EMAIL bsondgeroth@dist102.org</p> <p>MATRIX TYPES: WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL- SLUDGE NAS- SOLID LGHT- LEACHATE</p> <p>OTHER:</p>	<p>MEANS SHIPPED</p> <p>DATE SHIPPED</p>	<p>3 ANALYSIS REQUESTED</p> <p style="text-align: center;">LEAD 200.8</p>	<p>4 (FOR LAB USE ONLY)</p> <p>LOGIN # _____</p> <p>LOGGED BY: _____</p> <p>LAB PROJ. # _____</p> <p>TEMPLATE: _____</p> <p>PROJ. MGR.: KURT STEPPING</p> <p>DATE/TIME LAST USED 10/24/17 7PM</p>																																																																		
<p>2 SAMPLE DESCRIPTION (AS YOU WANT ON REPORT)</p>		<p>DATE COLLECTED</p> <p>TIME COLLECTED</p> <p>SAMPLE VOLUME COLLECTED</p>	<p>MATRIX TYPE</p> <p>BOTTLE COUNT</p>	<p>DATE RESULTS NEEDED</p>	<p>6 <small>The sample temperature will be measured upon receipt at the lab. By initialing this area you request that the lab notify you, before proceeding with analysis, if the sample temperature is outside of the range of 0.1-5.0°C. By not initialing this area you allow the lab to proceed with analytical testing regardless of the sample temperature.</small></p>																																																																		
<p>5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) NORMAL RUSH <small>(RUSH TAT IS SUBJECT TO PDC LABS APPROVAL AND SURCHARGE)</small></p> <p>RUSH RESULTS VIA (PLEASE CIRCLE) FAX PHONE <small>FAX # IF DIFFERENT FROM ABOVE: PHONE # IF DIFFERENT FROM ABOVE:</small></p>		<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>DATE COLLECTED</th> <th>TIME COLLECTED</th> <th>SAMPLE VOLUME COLLECTED</th> <th>MATRIX TYPE</th> <th>BOTTLE COUNT</th> <th>DATE RESULTS NEEDED</th> </tr> </thead> <tbody> <tr> <td>10/25/17</td> <td>6:07 AM</td> <td>250 ml</td> <td>DW</td> <td>1</td> <td>X</td> </tr> <tr> <td>10/25/17</td> <td>6:09 AM</td> <td>250 ml</td> <td>DW</td> <td>1</td> <td>X</td> </tr> <tr> <td>10/25/17</td> <td>6:11 AM</td> <td>250 ml</td> <td>DW</td> <td>1</td> <td>X</td> </tr> <tr> <td>10/25/17</td> <td>6:13 AM</td> <td>250 ml</td> <td>DW</td> <td>1</td> <td>X</td> </tr> <tr> <td></td> <td></td> <td>ml</td> <td>DW</td> <td>1</td> <td>X</td> </tr> <tr> <td></td> <td></td> <td>ml</td> <td>DW</td> <td>1</td> <td>X</td> </tr> <tr> <td></td> <td></td> <td>ml</td> <td>DW</td> <td>1</td> <td>X</td> </tr> <tr> <td></td> <td></td> <td>ml</td> <td>DW</td> <td>1</td> <td>X</td> </tr> <tr> <td></td> <td></td> <td>ml</td> <td>DW</td> <td>1</td> <td>X</td> </tr> <tr> <td></td> <td></td> <td>ml</td> <td>DW</td> <td>1</td> <td>X</td> </tr> </tbody> </table>		DATE COLLECTED	TIME COLLECTED	SAMPLE VOLUME COLLECTED	MATRIX TYPE	BOTTLE COUNT	DATE RESULTS NEEDED	10/25/17	6:07 AM	250 ml	DW	1	X	10/25/17	6:09 AM	250 ml	DW	1	X	10/25/17	6:11 AM	250 ml	DW	1	X	10/25/17	6:13 AM	250 ml	DW	1	X			ml	DW	1	X			ml	DW	1	X			ml	DW	1	X			ml	DW	1	X			ml	DW	1	X			ml	DW	1	X	<p>7 RELINQUISHED BY: (SIGNATURE) <i>Byron Sondgeroth</i></p> <p>DATE 10/30/17</p> <p>TIME 1:29 PM</p> <p>RECEIVED BY: (SIGNATURE)</p> <p>DATE</p> <p>TIME</p>	<p>8 COMMENTS: (FOR LAB USE ONLY)</p> <p>SAMPLE TEMPERATURE UPON RECEIPT 21 °C</p> <p>CHILL PROCESS STARTED PRIOR TO RECEIPT SAMPLE(S) RECEIVED ON ICE PROPER BOTTLES RECEIVED IN GOOD CONDITION BOTTLES FILLED WITH ADEQUATE VOLUME SAMPLES RECEIVED WITHIN HOLD TIME(S) <small>(EXCLUDES TYPICAL FIELD PARAMETERS)</small> DATE AND TIME TAKEN FROM SAMPLE BOTTLE</p> <p style="text-align: right;"> <input checked="" type="checkbox"/> YES <input checked="" type="checkbox"/> NO <input type="checkbox"/> FOR N <input type="checkbox"/> FOR N </p>
DATE COLLECTED	TIME COLLECTED	SAMPLE VOLUME COLLECTED	MATRIX TYPE	BOTTLE COUNT	DATE RESULTS NEEDED																																																																		
10/25/17	6:07 AM	250 ml	DW	1	X																																																																		
10/25/17	6:09 AM	250 ml	DW	1	X																																																																		
10/25/17	6:11 AM	250 ml	DW	1	X																																																																		
10/25/17	6:13 AM	250 ml	DW	1	X																																																																		
		ml	DW	1	X																																																																		
		ml	DW	1	X																																																																		
		ml	DW	1	X																																																																		
		ml	DW	1	X																																																																		
		ml	DW	1	X																																																																		
		ml	DW	1	X																																																																		